



012

CERTIFICATE OF REGISTRATION

This is to certify that

Dorplan Contracts Ltd

Bexwell House
Karoo Close, Bexwell Business Park
Downham Market
Norfolk
PE38 9GA

Meets the requirements of the BM TRADA **Q-Mark Fire Door
Manufacture** scheme to **STD 006**

Steve Roberts
Product Certification Operations Manager
For and on behalf of BM TRADA

Certificate Number

1554

Date of Initial Certification

30 September 2019

Date of Last Issue

6 July 2022

Date of Expiry

29 September 2025

BM TRADA is a trading name of Warringtonfire Testing and Certification Limited, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA, UK
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com

Registration Schedule

Branch
Dorplan Contracts Ltd

Address
Bexwell House, Karoo Close
Bexwell Business Park
Downham Market
Norfolk
PE38 9GA

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this Q-Mark certified company are listed on the Q-Mark certificate along with the latest revision status. They are either used in isolation, or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Type	FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Integrity Period	Test Type
Fire	N/A	-	-	-	-	-
Smoke	N/A	-	-	-	-	-

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the Q-Mark certificate. The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Type	FoA Report	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	Test Type
Fire	Chilt/A02066	Falcon Panel Products Ltd	Strebor® 44 Doorsets (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	Chilt/A02067	Falcon Panel Products Ltd	Strebor® 54 Doorsets (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	WF407090	Falcon Panel Products Ltd	Strebor® 44/ Strebor® 54/ Stredor® 44/ Stredor® 54 30 Minute Front Entrance Doorsets (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	WF427764	Falcon Panel Products Ltd	Strebor® 54/ Stredor® 54 60 minute Front Entrance Doorsets (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	Chilt/A01204	Halspan Limited	Optima 30 (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	Chilt/A01205	Halspan Limited	Optima 60 (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	FEA/F97174	Halspan Limited	Prima 30 (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	FEA/F96103	Halspan Limited	Prima 60 (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	FEA/F98164	Pacific Rim Wood Ltd	Flamebreak 30 (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	FEA/F02141	Pacific Rim Wood Ltd	Flamebreak 60 (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	FEA/F99112A	Vicaima Ltd	FD30 – Flaxboard or chip core (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	Chilt/A13093	Vicaima Ltd	Vicaima Halspan 60 Doorsets (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	BMT/CNA/F15084	Winkhaus UK Ltd	Winkhaus Timber Frame with Halspan Blank (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-	-	-
Fire	BMT/CNA/F15084	Winkhaus UK Ltd	Winkhaus Timber Frame with Halspan Blank (Unglazed only)	60min	BS 476 Pt22
Smoke	N/A	-	-	-	-

Test Reports

Test reports are listed on the Q-Mark certificate. They cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Type	Test Report	Owner of Test Report	Doorset Description	Integrity Period	Test Type
Fire only	N/A	-	-	-	-